

Reaction to fire



The applicant: **WECO B.V.**  
HANDEISWEG 33  
NL-7461JJ RIJSSEN - OVERIJSEL

is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the report N° 2016AN1641



**aitex**  
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:  
CONSTRUCTION PRODUCTS**

N° 16AN1641

The sample reference:

**“AQUACRYLIC WALLCOVERING”**

has been tested according to the standards UNE-EN ISO 11925-2:2011 (equivalent to EN ISO 11925-2:2010) and UNE-EN 13823:2012 (equivalent to EN 13823:2010). The classification according to standard UNE-EN 13501-1:2007+A1:2010 (equivalent to EN 13501-1:2007+A1:2010) is:

**“B-s1,d0”**

Alcoy, July 26th 2016.

**Raquel Muñoz González**  
CHIEF OF INNOVATION AREA