

# **EST REPORT**

REPORT NUMBER: 100269789MID-001
ORIGINAL ISSUE DATE: December 2, 2010
REVISED DATE: N/A

#### **EVALUATION CENTER**

Intertek 8431 Murphy Drive Middleton, WI 53562

Dickson Saint Clair 415 avenue de Savoie 38110 St Clair de la Tour France

PRODUCT EVALUATED: JET TEX EVALUATION PROPERTY: NFPA 701-10, METHOD 2 STANDARD METHODS OF FIRE TESTS FOR FLAME PROPAGATION OF TEXTILES AND FILMS

Report of Testing: JET TEX

NFPA 701-10, METHOD 2

Standard Methods of Fire Tests for Flame Propagation

Of Textiles and Films

"This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program."





# 1 Table of Contents

1	Tak	ole of Contents	. 2
		oduction	
		st Samples	
		SAMPLE SELECTION	
	3.2.	SAMPLE AND ASSEMBLY DESCRIPTION	. 3
4	Tes	sting and Evaluation Methods	. 3
	4.1.	TEST STANDARD 1	. 3
5	Tes	sting and Evaluation Results	. 4
	5.1.	RESULTS AND OBSERVATIONS	. 4
6	Col	nclusion	. 5



12/2/2010 Page 3 of 8

## 2 Introduction

Intertek has conducted testing for Dickson St. Claire, on JET TEX, to assess the propagation of flame beyond the area exposed to the ignition source. Testing was conducted in accordance with NFPA 701-10, Method 2 - Standard Methods of Fire Tests for Flame Propagation of Textiles and Films. This evaluation began December 2, 2010 and was completed December 2, 2010.

# 3 Test Samples

#### 3.1. SAMPLE SELECTION

Samples were submitted to Intertek directly from the client. Samples were not independently selected for testing. Samples were received at the Evaluation Center on November 15, 2010.

#### 3.2. SAMPLE AND ASSEMBLY DESCRIPTION

Ten (10) specimens were prepared by measuring 125 mm x 1200 mm  $\pm$  25 mm. Samples were then conditioned in an oven at  $105^{\circ}\text{C} \pm 3^{\circ}\text{C}$  for no less than 1 hour but no more than 3 hours before testing.

## 4 Testing and Evaluation Methods

#### 4.1. TEST STANDARD 1

Ten (10) specimens of material 4.9 in. x 47.25 in. are cut with their long dimension parallel to the length direction ("with" machine). The test specimens are conditioned to 220-225 € (105-108 ℃) for not less than one hour and not more than 3 hours. Specimens are removed from the oven one at a time and tested immediately. The specimens are supported with clips in a three-sided vertical column and exposed to an 11" flame for two minutes. The flame impinges approximately 7 inches on the specimen.

No specimen continued flaming for more than two seconds. Length of char did not exceed 17.1 inches from the bottom edge of the specimen. No flaming on floor of apparatus for longer than two seconds.



 Dickson St. Claire
 12/2/2010

 Project No. 100269789MID-001
 Page 4 of 8

# **Testing and Evaluation Results**

## 4.2. RESULTS AND OBSERVATIONS

All samples passed; there was no afterflame or floor flame.



12/2/2010 Page 5 of 8

## 5 Conclusion

Intertek has conducted testing for Dickson St. Claire, on JET TEX, to assess the propagation of flame beyond the area exposed to the ignition source. Testing was conducted in accordance with NFPA 701-10, Method 2- Standard Methods of Fire Tests for Flame Propagation of Textiles and Films. This evaluation began December 2, 2010 and was completed December 2, 2010.

#### **INTERTEK**

Reported by:

Andrew Maximiuk

Indu Malle

Lab Technician II, Verification Center and Small Scale Lab

Reviewed by:

Rhonda Byrne

**Operations Manager, Middleton Facility** 



 Dickson St. Claire
 12/2/2010

 Project No. 100269789MID-001
 Page 6 of 8

# **APPENDIX A**



 Dickson St. Claire
 12/2/2010

 Project No. 100269789MID-001
 Page 7 of 8

## TEST RESULTS

	Afterflame Duration	Floor Flaming	Char Length (in.)
Specimen #	(sec.)	(sec.)	. ,
1	0	0	7.25
2	0	0	5.25
3	0	0	5.75
4	0	0	6.75
5	0	0	8.00
6	0	0	6.75
7	0	0	5.25
8	0	0	8.00
9	0	0	4.25
10	0	0	5.25
Average	0	0	6.25



12/2/2010 Page 8 of 8

# **REVISION SUMMARY**

DATE	SUMMARY
December 2, 2010	Original Report